

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No - 847

DATE- 21-1-25

It is certified that an inspection team headed byJen Mahima Gupta..... from P.H.E.D Malviya Nagar Jaipur inspected the St. Anselm's Pink City School, Malviya Nagar, Jaipur on 21.01.2025 and found that the St. Anselm's Pink City School, Malviya Nagar, Jaipur has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the NATIONAL SCHOOL SANITION MANUAL OF Central Govt.

The above certificate is valid for a period of 12 months.

Encl. Superintending Chemist PHED Lab

Sample Test report Bact. Letter No. 4017 Date 20.01.2025

Sample Test report Chem. Letter No. 4011 Date 20.01.2025

Mahima
Jen

for

Signature with seal.....

Name: PRIYA BARIA

Designation: Assistant Engineer

PHED City Sub. Dn- V(S)

Malviya Nagar

Jaipur

Copy to:

Principal,

St. Anselm's Pink City School

Malviya Nagar, Jaipur

for

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: La/Bact/2024-25/ 4017

Dated: 20/1/25


To
Anslem's Pink City School
Malviya Nagar
Jaipur

Reference : - Your Application on dated 15/1/2025
GRN NO. : -99484087 Paid on Date 15/1/2025

Distt: Jaipur
Tehsil: Jaipur

Sample No.	Date of Collection	Date of Examination	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:102 ----- 3032	15/1/2025	15/1/2025	Jaipur	RO Water St. Anslem's Pink City School Malviya Nagar	Nil	Nil	Satisfactory

Remark-1-Not Valid for water quality Legal cases
2- The Sample was not collected by this laboratory


Superintending Chemist(HM & Jaipur City)
PHED, Laboratory, Jaipur

No: Lab/Bact/2024-25/ Dated:
Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur

				Superintending Chemist (HM & Jaipur City) PHED, Laboratory, Jaipur
Sample No.	Date of Collection	Date of Examination	Particulars of Samples	
P:102 ----- 3032	15/1/2025	15/1/2025	RO Water St. Anslem's Pink City School Malviya Nagar	

OFFICE OF THE CHIEF CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2024-2025/ 4011

Date: 20/01/2025

To,
Principal
St. Anselm.s Pink City
School, Malviya Nagar
Jaipur

The Sample was not Collected
by this Laboratory

Not Valid for water
quality i Legal Cases

Date of Receipt: 15/01/2025

Particulars			RO Water
value as per I.S.:10500/2012			
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			15.01.2025
Lab. Sample No.			P-159
1. pH	6.5-8.5	6.5-8.5	7.50
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	50
6. Total Hardness (as CaCo3) mg/l	200	600	100
7. Calcium (as Ca) mg/l	75	200	16
8. Magnesium (as Mg) mg/l	30	100	15
9. Chloride (as Cl-) mg/l	250	1000	40
10. Nitrates (as NO3-) mg/l	45	45	12
11. Sulphate(as So4- 2)mg/l	200	400	12
12. Total Dissolved Solids mg/l	500	2000	154
13. Fluoride mg/l	1.00	1.5	0.11
14. Iron mg/l	1.0	No Relaxation	Nil
15. Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2. Tested Results Relate only to The Samples send yo



Superintending Chemist (Heavy Metal)

P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2024-2025/

Date:

Copy to:- 1. The Chief Chemist, PHED Raj. Jaipur


Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur